

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

**1328-CPR-0756**

In compliance with Regulation (EU) no. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### FIRE DETECTION AND FIRE ALARM SYSTEMS: SOUNDER

Intended use	Type Reference	Colour	Technical characteristics
Fire safety	WMS99	Red	Type A (Indoor use)
	WMS69	White	

produced by

**SYNAPS Technology S.r.l.**

Via Pietraferrata 9/1, 34147 Trieste, Italy

and produced in the manufacturing plant(s)

**SYNAPS Technology S.r.l.**

Via Pietraferrata 9/1, 34147, Trieste, Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006**

under system 1 are applied and that  
the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2019-04-15 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Almada, 2019-04-15



Francisco Barroca  
General Manager

